



Control Number: 51415



Item Number: 549

Addendum StartPage: 0

MAY 19 PM 1:57

**SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE TO COMMISSION
STAFF'S TENTH REQUEST FOR INFORMATION**

Question No. STAFF 10-8:

Knox Lee Outage – Quantify which expenses occurred as a result of the substation fire and explain whether this event was:

- a. Separate from the August 18, 2019 outage event;
- b. During the August 18, 2019 outage event;
- c. As a result of the August 18, 2019 outage event; and/or
- d. Immediately after the August 18, 2019 outage event.

Response No. STAFF 10-8:

The August 18, 2019 Knox Lee Unit 5 forced outage, which lasted approximately 4 hours, was due to a vegetation related transmission outage in the area. Knox Lee Unit 5 was offline at the time of the event. No expenses were incurred.

Prepared By: Tara D. Beske

Title: Regulatory Consultant Staff

Sponsored By: Monte A. McMahon

Title: VP Generating Assets SWEPCO